# PLANT COMPLIANCE SURVEY EMERGENCY EYEWASH

World Leaders in Emergency Eye Care



## EYEWASH COMPLIANCE GUIDELINES: DO YOU KNOW WHAT TO LOOK FOR?

#### **High Incident Chemical Eye Injury Areas:**

The following areas must meet Emergency Eyewash Compliance Guidelines according to ANSI Z358.1.2009 Check MSDS sheets for specific requirements, or call your distributor or Honeywell representative for more information.



Requirements

#### FREE PLANT COMPLIANCE SURVEY INSTRUCTIONS

Simple, easy-to-follow instructions for scheduling Free Plant Compliance Surveys are as follows:

- 1. Fill in company information under "Sponsoring Vendor," "Contact," "Phone," and "Fax."
- 2. Fax the attached form to your end-users.
- **3.** Await reply of interested customers.
- **4.** Contact your HSP Territory Sales Manager to schedule joint end-user calls with your sales representative.

Any questions, please call Customer Care at (800) 430-5490.

#### **Recommended Tools for Scheduled Visit**

- · End-user site / floor plan of facility
- · Evaluation forms
- · Eyewash test gauge
- · Tape measure
- Bucket
- · Shower tester
- · Watch with second hand
- Thermometer
- · Copy of ANSI Standard

#### PLANT COMPLIANCE CHECKLIST

Replacement Parts – Possible Problem Areas			Service Required			
	Broken/missing dust cover		Align eyewash heads			
	No striping		Tighten push flags			
	Sign missing		Attach foot treadle chain			
	Pull rod damaged		Clear or mark floor area			
	Replace head(s)		Align shower head/eyewash			
	Replace shower head		Add lighting to emergency station			
	Replace bowl		Add shower/modesty curtain			
	Replace foot treadle		Replace self closing valve with stay open valve			
	Replace treadle chain		Service in-line filters			
	Replace flow control		Clean and refill self contained per manufacturers' instruction			
	Replace pull strap		Eyewash nozzles at improper height – should be 33" to 45" from floor and 6" from wall or nearest obstruction			
	Replace fill cap		Shower at improper height – should be 82" to 96" from floor, handle to be 69" from where user stands			
	Replace cartridges model Fendall Pure Flow 1000®		Eyewash and shower do not run simultaneously			
	Replace cartridges model Fendall 2000 <sup>™</sup>		Area too cold – requires heated unit (i.e. Porta Stream #310)			
	Eyewash required not present		Move eyewash closer to hazard to comply with ANSI Z358.1-2009 (10 seconds from hazard)			
	Missing inspection tag					
	Missing nozzle covers					

#### **Performance Requirements:**

- All equipment must be 10 seconds from hazard.
- All equipment must be simple to operate and activate in one second or less.
- Primary device provides 15-minute flush time at .4 gpm.
- Secondary device is to be used to support primary devices, **NOT** replace them.
- \* Don't forget! Irrigation should continue while injured is transported to medical assistance after the 15-minute flush.

Note: All employees MUST be instructed on the location, proper use and application of all equipment.



# PORTABLE EYEWASH STATION COMPLIANCE SURVEY

Date:	
End User:	

**Recommended:** Monthly Visual Checks

Location:		Status	Recommendations
Check Unit	Check for Obstruction, Location within 10 Seconds and Condition		
Check Cartridges	List Expiration Date(s)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Unit	Check for Obstruction, Location within 10 Seconds and Condition		
Check Cartridges	List Expiration Date(s)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Unit	Check for Obstruction, Location within 10 Seconds and Condition		
Check Cartridges	List Expiration Date(s)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Unit	Check for Obstruction, Location within 10 Seconds and Condition		
Check Cartridges	List Expiration Date(s)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Unit	Check for Obstruction, Location within 10 Seconds and Condition		
Check Cartridges	List Expiration Date(s)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Unit	Check for Obstruction, Location within 10 Seconds and Condition		
Check Cartridges	List Expiration Date(s)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		

Place an X to indicate everything is OK and up to standards.

Place an N/C for non-compliance and list what actions are needed to bring up to standards.



# PORTABLE EYEWASH STATION COMPLIANCE SURVEY

Date:	
End User: _	

Recommended: Weekly Visual Checks

Location:		Status	Recommendations
Check Eyewash/	Shower for Flow Run for up to One Minute		
Check Aerators	Check and Clean Aerators (If Needed)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Eyewash/	Shower for Flow Run for up to One Minute		
Check Aerators	Check and Clean Aerators (If Needed)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Eyewash/	Shower for Flow Run for up to One Minute		
Check Aerators	Check and Clean Aerators (If Needed)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Eyewash/	Shower for Flow Run for up to One Minute		
Check Aerators	Check and Clean Aerators (If Needed)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Eyewash/	Shower for Flow Run for up to One Minute		
Check Aerators	Check and Clean Aerators (If Needed)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		
Location:			
Check Eyewash/	Shower for Flow Run for up to One Minute		
Check Aerators	Check and Clean Aerators (If Needed)/Recent Inspection Date		
Check Signage	Verify Signage is Present and Visible		

Place an X to indicate everything is OK and up to standards.

Place an N/C for non-compliance and list what actions are needed to bring up to standards.

### **Honeywell**

. , -	Jillinelita.					
Ne are very in Honeywell Sat	terested in your <b>c</b> ety Products Sale	<b>:andid</b> comme ss Representat	ents as it applies i tive at:	to the Plant Complia	nce Survey. Please	fax or e-mail your reply to yo
	☐ Email:	☐ Fax:				
	Date of Re	ply:				
Distributor (	Comments:					

#### Sperian is now Honeywell

Rev. 7/2011

Sperian Protection Americas, Inc., A Honeywell Company | 900 Douglas Pike, Smithfield, RI 02917 Phone: US 1.800.430.5490 | Canada 1.800.430.5605 | Fax: US 1.800.332.1330 | Canada 1.800.680.5343 www.honeywellsafety.com